

Imperial College London

FIRE SERVICES
ROOM 174, SHERFIELD BUILDING

Code of Practice

Revision No:

Date:

8th May 2008

Skips

Ideally externally located skips should be located at least 8 metres away from buildings. Contractor's skips should be located in compounds protected by hoarding or Heras fencing.

If space restrictions necessitate any part of skips being kept closer than 4 m from buildings, then they should be of the enclosed lidded variety.

Chief Fire Officer